

# Hydropower Plants: Generating and Pumping Units

## Series 2

### GENERAL STUDY OF HYDRO POWERPLANT

The studied hydro-electric installation, whose layout is shown in Figure 1, is located in South America.



*Figure 1: Layout of the hydro-electric installation*

The rated discharge of the power plant  $Q$  is  $50 \text{ m}^3 \text{ s}^{-1}$ . The gross head is considered as constant throughout the year and equal to  $300 \text{ m}$ . The value of the water density is  $\rho = 1'000 \text{ kg}\cdot\text{m}^{-3}$  and the gravity acceleration is  $g = 9.805 \text{ m}\cdot\text{s}^{-2}$ . The global efficiency of the power station (i.e. without considering the losses between B and I) is  $\eta = 0.91$ . For the purpose of simplification, the piping system is considered as a simplified penstock line, as illustrated in Figure 2. In this section, the only considered specific energy losses in the hydraulic circuit from B to I are the regular specific energy losses between III and II. Use the length of the penstock  $L = 5'400 \text{ m}$ .




Figure 2: Simplified schematics of the hydro-electric installation

- 1) Express the potential power by using the relevant variables.
- 2) Express the distributed specific energy losses in the penstock  $gH_{r\_penstock}$  as a function of the local loss coefficient  $\lambda$ , the length of the penstock  $L$ , the penstock diameter  $D$ , and the discharge  $Q$ .
- 3) Considering the distributed specific energy losses in the penstock, express the hydraulic power  $P_h$  at point I.
- 4) The global efficiency  $\eta$  is the result of a combination of several phenomena which limit the use of the hydraulic power  $P_h$  by the hydraulic machine, thus reducing the final output power  $P$ . Provide an answer to the following questions:
  - a. Is the transferred power  $P_t$ , also called extracted power, larger or smaller than the hydraulic power  $P_h$ ? Justify your answer by giving a list of the phenomena that are responsible for this difference, and indicate which efficiency sub-terms  $\eta_i$  of the global efficiency  $\eta$  are involved.
  - b. Is the mechanical power  $P_m$  larger or smaller than the output power  $P$ ?  
Why?
  - c. To evaluate the electrical power which is actually provided to the grid, calculating the output power  $P$  is not enough. A further efficiency sub-term (which is however not included in the global efficiency  $\eta$ ) must be considered. Why?
- 5) Using the global efficiency  $\eta$ , express the output power  $P$  using the parameters introduced in questions 1) and 2).
- 6) Let's move now to the energy state of the flow discharge. Start by expressing the gauge pressure of a fluid in function of the absolute and the atmospheric pressures.
- 7) Performing an energy balance between the pressure, kinetic energy and potential energy components of the discharge flowing in the penstock, express the total gauge

pressure  $p_{tot}(l) = p_{gauge}(l) + \frac{1}{2}\rho u^2(l)$  as a function of  $L$ ,  $l$ ,  $Z_I$  and  $Z_{III}$ . Consider  $l$  as the coordinate which describes the longitudinal position in the penstock ( $l = 0$  in *III*, and  $l = L$  in *II*),  $p_{gauge}(l)$  the gauge pressure and  $\frac{1}{2}\rho u^2(l)$  the dynamic pressure. Assume that the elevation in *III* is approximately the same as at the surface of the upper reservoir,  $Z_{III} \cong Z_B$ , and neglect the specific energy losses term.

- 8) In your opinion, could the dynamic pressure term be replaced by a constant? If yes, which geometrical characteristic must the penstock have?
- 9) Let's now put some numerical values on these results. Considering a pipe diameter  $D = 3$  m and using the values listed in Table 2, calculate the following values :
  - a. The output power  $P$  in kW.
  - b. The electricity generation in kWh for one year.
  - c. The annual sales of the electricity (neglecting the energy losses in the generator).

*Table 2. Specific values of the penstock*

parameter	value
$\lambda$	0.0100
<i>Annual productivity</i>	50%
<i>Electricity Unit Price</i>	0.06 CHF/kWh