
Water reuse and desalination

Urs von Gunten

Eawag, Swiss Federal Institute of Aquatic Science and Technology

EPFL, Ecole Polytechnique Fédérale de Lausanne

Heat wave in summer 2018 – Is this the future of Switzerland/Central Europe?




Water crisis Cape Town 2017/2018





Water crisis in Capetown: They barely made it!



Water crises worldwide



- Windhoek (Namibia, end of 1970s)
- Australia (2000s, Perth, Brisbane)
- California (drought: 2011-2017, 2019-?)
- South Africa (2017/2018)
- Italy, Spain, Greece
- Singapure (water autonomy)

• ...

Drought in Switzerland in 2018 (2022): Most severe in a century




Precipitation in Switzerland – Forecast 2060

Precipitation Deviation (%)

Abweichung von der Normperiode 1981-2010

Summer 2060

RCP8.5 Mittlere Schätzung




Precipitation | Deviation (%)

Abweichung von der Normperiode 1981-2010


Winter 2060

RCP8.5

Mittlere Schätzung



Water crisis in Switzerland? Water balance in Switzerland





Water Reuse

Conserve Water

Ocean water desalination



Reverse Osmosis

Optimize irrigation Industry

Approaches to solve water shortages

Rain water harvesting

Rory M. Shaw Wetland Park, LA





Multiple water resources

Artificial groundwater recharge




The urban water cycle









A resilient solution through multiple water resources Water provision from the water supply Zurich to 67 communities






Schaad, TA, Sept. 2018, A. Peter WVZ, Jan. 2019, http://www.hydrodaten.admin.ch/de/2104.html https://www.stadt-zuerich.ch/dib/de/index/wasserversorgung/wasserverteilung/versorgungsgebiet.html







Use of groundwater in Switzerland: Proportion of artificial recharge and bank filtration


> 50000 Inhabitants



< 10000 Inhabitants









The Rhine River: Water resource and "Sewer" for 50 Mio people Drinking water from the Rhine river: Indirect usage of recycled wastewater

- Proportion of recycled wastewater
 Basel ca. 10%
 - The Netherlands ca. 30 60%
- Bank filtration or artificial infiltration as important barrier
- Physical-chemical und biological treatment depends on the water quality (CH<D<NE)



"Unintended reuse": Drinking water treatment as a multibarrier system



Protection of water resources

- Active watershed management
- Riverbank filtration
- Artificial recharge
- Groundwater

Water treatmentMultibarrier treatm

Multibarrier treatment (ozone, ultraviolet light, advanced oxidation processes, biological filtration, membranes, chlorine)

Distribution system

- Maintain and replace infrastructure
- ·Water-quality monitoring
- Hydraulic integrity

Resources protection

Treatment


Distribution

Rosario-Ortiz, F., Rose, J., Speight, V., von Gunten, U. and Schnoor, J. (2016) How do you like your tap water? Science 351(6276), 912-914.


Water Reuse Systems

Case study 1
Perth, Western Australia


Projection for Rainfall in Australia for 2030



Average rainfall and recharge for Gnangara Mound



Projection of water use in the Perth metro area 255GL (0.255 km³) shortfall by 2060




Based on availability of current sources

By 2020 - 5GL shortfall


By 2030 - 75GL shortfall

By 2060 - 255 GL shortfall

Wastewater flows increase with population



Intended (in)direct potable reuse



Water reuse trial plant (Perth, WA)


WWTP Effluent Screening

















Wastwater-recycling in Perth – Western Australia






What is the perception of recycled wastewater in the media/in the public?



By Paul Lachine



Source: http://www.hcn.org/issues/354/17227

64THE NATION Groundwater recharge in WA Contaminants to be recycled in taps

ACCEPTED WASTE These are allowed to be dumped into Brisbane's sewers Grease and oil Nitrogen Phosphorus Sulphate Aluminium ecycled wyater what you could be drinkking Manganese Pesticides Arsenic Lead Mercury Cohalt

Cvanide

A WIDE range of industrial contaminants including pesticides, cyanide, grease and fertilisers can be included in waste that will be recycled as drinking water wide range of contaminants. for the 2.6 million residents of southeast Queensland.

The Bligh Government insists health risk as the levels are low.

Industrial and hospital effluent dumped in the sewers of Brisbane and Îpswich will constitute 12 per amended to take account of the cent of the wastewater to be recycled water plan.

pumped to Wivenhoe Dam, Bris-

Brisbane City Council guidelines covering the disposal of socalled trade waste to the sewer stipulate maximum levels for a

The guidelines are designed to "protect the environment, the health of sewerage workers, the the contaminants will not pose a operation and maintenance of the conveyance system and wastewater treatment facilities".

The guidelines have not been

Six toxic organochlorine pes-The first recycled water will be tides, including DDT and dieldrin, are allowed in trade waste at bane's main storage facility, in very low levels — up to 0.1mg/L. February. The quantity will rise Organochlorine pesticides have

the environment for many years.

Higher levels of less toxic organophosphate pesticides including malathion and azinphos can be dumped, along with up to 50mg/L of formaldehyde and 30mg/L of petroleum hydrocarbons. The council guidelines say formaldehyde and petroleum hydrocarbons can "adversely affect the safety of operations and maintenance personnel".

The guidelines list 13 allowable metals including arsenic, lead, mercury, cobalt and zinc.

Bromine, sulphide and cyanide, which "may produce toxic atmospheres in the sewer", are allowed, as are ammonia, nitro-

health concerns and remain in oil. The guidelines allow "gross vented hazardous material from solids" to be dumped if they are less than 20mm.

Treatment processes that may be required before dumping in the sewer include the neutralisation of acidic wastes and the chemical

Food preparation wastes must pass through an approved grease trap before reaching the sewer.

Polluted water from the motor trade may result from the degreasing of mechanical parts, the washing of workshop floors contaminated with hydrocarbons, and removing paint wastes from smash repair shops.

Queensland Water Commission chief executive John Bradley

entering sewage networks.

"Councils issue approvals for trade waste after considering the relative risk of the waste to the sewage treatment system and the effluent water quality," Mr Bradley said.

Referring to a mixup at the Gold Coast's Pimpama treatment plant which resulted in unsafe recycled water being put in drink- as a last resort, echoing the ing water, Mr Bradley said the sentiments of National Health Western Corridor Recycled Water Scheme was safe. "The water chief Don Bursill, which system that will produce purified water will have real-time online monitoring that will shut down the plant immediately if regulated standards are not being met."

fluoridated water. Premier Anna Bligh said the only thing that would stop the recycling plan would be overflowing dams.

"This is something that we can be proud of, not fearful of," Ms

Opposition Leader Lawrence Springborg said recycled water should be used for drinking only and Medical Research Council were reported in The Australian yesterday. "If something goes wrong, there's a breakdown in the system; you've got nowhere to go," Mr Springborg said.

1001 : Chadic to take the

2 · SATURDAY, FEBRUARY 28, 2009

Inside

News

thewest.com.au

THE WEST AUSTRALIAN

OPINION 20-21

Editorial: Burmese leaders should be charged with crimes against humanity. 20 Zoltan Kovacs: Education bingo a diversion from the drone of "edspeak". 20 Paul Murray: Top water scientist honoured and snubbed by WA Government. 21

WORLD 24-48

China: Relatives seek justice for Tiananmen Square victims. Lebanon: Investigators try to get convictions for Rafik Hariri's assassination. 26 US: Senior CIA official jailed for corruption.

BUSINESS 56-65

Handout: Pacific Brands may still receive millions of dollars in grants from the Federal Government later this year.

Treadgold: Every Perth property owner is potentially affected by a tug of war over

SPORT 105-120

Cricket: WA Sheffield Shield chances hanging by a thread. Olympics: After 100 years, swimmer recognised as Australia's greatest. Football: Charity derby failing to inspire fans of Eagles and Dockers.

CLASSIFIEDS 71-103

Recycled sewage plan for WA taps

ALANA BUCKLEY-CARR EXCLUSIVE

Recycled sewage will constitute as much as 10 per cent of Perth's drinking water by 2030 under a new plan for the State's water supply.

In a draft policy on future water supplies to be released next week, the Water Corporation has set a target of recycling 30 per cent of Perth's waste water by 2030 and as much as 60 per cent by 2060.

Water industry policy manager Meredith Blais said a quarter of

poses. But a three-year trial is due to begin late this year into recycling waste water for drinking.

"Recycling water for drinking is highly technical and complex from a regulatory perspective, given that this has only recently been considered a new potential source of drinking water in Australia," the report said.

"While highly feasible, ground water replenishment (recycling water for drinking) will require health and environmental approvals and signifi-

cant community support." In an alarming profile of how the

reduce water use but said more needed to be done to meet the 2030 aim of reducing current use by a quarter.

"Since 2001, the average water use per person has decreased by 20 per cent. This translates to a saving of approximately 61GL of water over the last seven years," the report said.


Sources independent of rainfall would have to be created, including tapping groundwater from the Collie coal basin and building desalination plants north and south of Perth.

But prices would also have to increase "to ensure they send appro-


Case study 2

Brisbane, Queensland Water recycling plans


Combined storage capacity of main dams in Brisbane (total capacity 1760 GL = 1.76 km³)



Water Reduction & Savings



Drinking water use in Germany Old and new member states



What happened next ...

- Public surveys suggested 70-75% support for water recycling to dam
- Detailed assessment of water quality with experts from around the world
- Concerted media campaign against the water recycling for drinking water
- A lot of rain...
- Public support dropping....
- State election new government
- Project put on hold...



And then...






Queensland: Wivenhoe dam during drought and flood In 2020 the recycling project is reconsidered again..

Closing the anthropogenic water: (in)direct potable reuse

- Technical feasibility has been demonstrated
- Process optimization for improvement and/or alternatives
- Public perception as an important factor (Singapore vs Australia)
- Scientists and engineers must be engaged in public debate and clearly communicate benefits and problems to allow an objective assessment

Desalination




Desalination / RO

Water scarcity is one of the most important problems of the future

Most problems occur in coastal regions → Rapid increase in desalination capacity

At present: total desalination capacity ca. 40 Mio m^3/day drinking water for ≈ 100 Mio people



Environmental concerns with Desalination

Ecological

- Perturbations at intake
- Discharge of the brine


High Energy consumption






Osmotic pressure

In principle, only water is transported: results in an *osmotic pressure*



Reverse osmosis

Applied pressure has to be higher than osmotic pressure



Osmotic pressure

Van't Hoff:

$$\Pi = \beta \cdot \frac{n_i}{V} \cdot R \cdot T = \beta \cdot c_i \cdot R \cdot T$$

```
П
          osmotic pressure [bar]
          amount of dissolved substances [mol]
n_i
          volume of the solution
V
                                        [L]
          universal gas constant = 8.3144 [J/mol/K] = 0.083144 [bar L /mol/K]
R
          absolute temperature
                                        [K]
          molar concentration of substance i [mol/L]
C_i
          = 1 + \alpha (v - 1)
          degree of dissociation
\alpha
          stoichiometric coefficient of the dissociation reaction
ν
          (number of ions formed from dissociation from 1 original salt [-])
```


Example: Calculation of Osmotic pressure


Osmotic pressure of seawater as NaCl-solution (other salts not taken into account) at 25 $^{\circ}$ C.

```
NaCl-content: 30 g/l; molar weight: Na = 23; Cl = 35.5 \alpha = 1; \nu = 2 (Na^+, Cl^-) \beta = 1 + \alpha (\nu - 1) = 1 + 1x(2-1) = 2 c_{NaCl} = \frac{30 \text{ g/L}}{(23 + 35.5) \text{ g/mol}} = 0.51 \text{ mol/L} \Pi = \beta \cdot \frac{n_i}{V} \cdot R \cdot T = \beta \cdot c_i \cdot R \cdot T
```

 $\Pi = 2 * 0.51 \text{ (mol/L)} * 8.3144 \text{ (bar L/mol/K)} * 298 \text{ K} = 25.4 \text{ bar}$

Energy requirement for desalination with RO





Total energy requirement: 3-4 kWh/m³ Δ E results from energy for pre-/post-treatment

Sea water: ca. 35g/L dissolved salts

Conclusions

- Worldwide there is an increasing pressure on water resources
- Water reuse is a viable option to solve/mitigate water scarcity in urban areas (acceptance issues, indirect vs direct potable reuse
- In coastal areas desalination is an alternative, however the energy demand is high
- To solve water scarcity problems, water use in agriculture and industry has to be considered as well
- Water reuse or desalination are too expensive for irrigation in agriculture (improvement of irrigation methods, adapted crops)